

Annexure- C

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. F.6(15)/AE/DWS/SD/AMP/2026-27/153

Dated: 10.6.26

It is certified that an inspection team headed by Barun Das, Research Assistant
(Name of officers with designation) from Amarpur Sub-Division Lab inspected the
Amarpur English Medium H/S School (Name & Address of the School) on
09/06/2026 (date of Inspection) and on the basis of Water Test Report (Attached) bearing No.
153 date 10.6.26 Of NABL LAB - NABL-DWT-0019
certified that the Amarpur English Medium H/S School (Name of School)
has safe drinking water facilities for the students and members of staff of the institution. School
is also maintains the hygienic sanitation condition in the school building and the campus as per
norms prescribed by the Central/ State / U.T .Govt.

This Certificate is valid till 09/06/2027

Signature with seal.....Assistant Engineer
Name.....DWS Amarpur Sub-Division
Designation.....Amarpur Gomati Tripura
Name & Address of the office/ Department.....

To

Principals
Amarpur English Med.
H/S School, Amarpur
(Name & Address of the institution)

Note: The certificate is to be issued by Authorized Officer/ PHED Lab/ Local bodies.

Govt. of Tripura
Office of the Assistant Engineer
DWS Sub-Division Amarpur
Amarpur, Gomati Tripura

No. F.6 (15)/AE/DWS/SD/ AMP/2026-27/ 153

Dated. 10 /06/2026

To,
The Principal,
Amarpur English Medium H/S School,
Amarpur Gomati Tripura,

Sub:- Water Testing Report.

Ref. F. No. 7(1)/AEMHSS/ESTT/AMP/22-520

Dt. 09/06/2026


Sir,

I am Sending herewith **02(Two) Nos.** Water Testing Report of Amarpur English Medium H/S School under DWS Sub-Division Amarpur.

This is for favour of your kind information and necessary action please.

Encl:- As Stated Above.

Yours faithfully


Assistant Engineer
DWS Sub-Division Amarpur
Amarpur, Gomati Tripura

GOVERNMENT OF TRIPURA
SUB-DIVISIONAL WATER TESTING LABORATORY
DWS SUB-DIVISION AMARPUR
AMARPUR, GOMATI TRIPURA

NABL-DWT-00113

REPORT ON PHYSICAL, CHEMICAL & BACTERIOLOGICAL ANALYSIS OF WATER SAMPLE

Source of Sample :- Tap Water Testing Report of Amarpur English Medium H/S School under DWS Sub-Division Amarpur.

Date of collection :- 09/06/2026

Date of Receipt of Sample: - 09/06/2026 (Clear Water)

Date of testing :- 09/06/2026

Sl.No	Description of test	Result.	Desired limit	Permissible limit.	Remarks
1)	Temperature in °C	34°C	-	-	
2)	Physical appearance	Clear	-----	-----	
3)	Colour in Hazen unit	-----	5	25	
4)	Turbidity in NTU	0.26 NTU	0.1 NTU	1.00 NTU	
5)	Taste & Odour	Agreeable	Agreeable	Agreeable	
6)	pH-Value	8.21	6.5 to 8.5	No relaxation	
7)	Total Alkalinity in mg/l as CaCO ₃	48.0 mg/l	200 mg/l	600 mg/l	
8)	Total Hardness in mg/l as CaCO ₃	72.0 mg/l	300 mg/l	600 mg/l	
9)	Total Iron in mg/l as Fe	0.1 mg/l	0.1 mg/l	0.3 mg/l	
10)	Chloride in mg/l as Cl	19.0 mg/l	250 mg/l	1000 mg/l	
11)	Total Solid in mg/l	-	2000	No relaxation	
12)	Total Dissolved Solid in mg/l(TDS)	38.0 mg/l	500	No relaxation	
13)	Total Suspended Solid in mg/l	-	05	No relaxation	
14)	Residual Chlorine as Cl in mg/l	-----	0.2	No relaxation	
15)	Nitrate in mg/l as NO ₃ -N	-----	45	100	
16)	Arsenic in mg/l as As	-----	0.05	No relaxation	
17)	Sulphate in mg/l as SO ₄	-----	200	400	
18)	Calcium in mg/l as Ca	16.8 mg/l	75	200	
19)	Magnesium in mg/l as Mg	7.29 mg/l	30	150	
20)	Electrical Conductivity in µs	-----	-	-	
21)	Total Fluoride in mg/l as F	-----	1.0	1.5	
22)	Total Acidity in mg/l	-----	<12	No relaxation	
23)	Dissolve Oxygen in mg/l	----	06 or >06	No relaxation	
24)	Total M.P.N. of Coliform/100 ml	0(Zero)	For Coliform organism: - 0(Zero)no./100ml	No relaxation	
25)	Total M.P.N. of Faecal Coliform/100 ml	-----	For Faecal Coliform Organism: - 0(Zero)no./100ml	No relaxation	

Analysis by:-

[Signature]
10/06/26

Chemists

Sub-Divisional Water Testing Laboratory
DWS Sub-Division Amarpur
Amarpur, Gomati Tripura

[Signature]
10/06/26

In-Charge

Sub-Divisional Water Testing Laboratory
DWS Sub-Division Amarpur
Amarpur, Gomati Tripura

[Signature]
10/06/26

Assistant Engineer
DWS Amarpur Sub-Division
Amarpur, Gomati Tripura

GOVERNMENT OF TRIPURA
SUB-DIVISIONAL WATER TESTING LABORATORY
DWS SUB-DIVISION AMARPUR
AMARPUR, GOMATI TRIPURA

REPORT ON PHYSICAL, CHEMICAL & BACTERIOLOGICAL ANALYSIS OF WATER SAMPLE

Source of Sample :- Aqua guard Water Testing Report of Amarpur English Medium H/S School under DWS Sub-Division Amarpur.

Date of collection :- 09/06/2026

Date of Receipt of Sample: - 09/06/2026 (Clear Water)

Date of testing :- 09/06/2026

Sl.No	Description of test	Result.	Desired limit	Permissible limit.	Remarks
1)	Temperature in °C	34°C	-	-	
2)	Physical appearance	Clear	-----	-----	
3)	Colour in Hazen unit	-----	5	25	
4)	Turbidity in NTU	0.25 NTU	0.1 NTU	1.00 NTU	
5)	Taste & Odour	Agreeable	Agreeable	Agreeable	
6)	pH-Value	7.35	6.5 to 8.5	No relaxation	
7)	Total Alkalinity in mg/l as CaCO ₃	38.0 mg/l	200 mg/l	600 mg/l	
8)	Total Hardness in mg/l as CaCO ₃	70.0 mg/l	300 mg/l	600 mg/l	
9)	Total Iron in mg/l as Fe	>0.1 mg/l	0.1 mg/l	0.3 mg/l	
10)	Chloride in mg/l as Cl	19.5 mg/l	250 mg/l	1000 mg/l	
11)	Total Solid in mg/l	-	2000	No relaxation	
12)	Total Dissolved Solid in mg/l(TDS)	33.1 mg/l	500	No relaxation	
13)	Total Suspended Solid in mg/l	-	05	No relaxation	
14)	Residual Chlorine as Cl in mg/l	-----	0.2	No relaxation	
15)	Nitrate in mg/l as NO ₃ -N	-----	45	100	
16)	Arsenic in mg/l as As	-----	0.05	No relaxation	
17)	Sulphate in mg/l as SO ₄	-----	200	400	
18)	Calcium in mg/l as Ca	16.0 mg/l	75	200	
19)	Magnesium in mg/l as Mg	7.29 mg/l	30	150	
20)	Electrical Conductivity in µs	-----	-	-	
21)	Total Fluoride in mg/l as F	-----	1.0	1.5	
22)	Total Acidity in mg/l	-----	<12	No relaxation	
23)	Dissolve Oxygen in mg/l	----	06 or >06	No relaxation	
24)	Total M.P.N. of Coliform/100 ml	0(Zero)	For Coliform organism: - 0(Zero)no./100ml	No relaxation	
25)	Total M.P.N. of Faecal Coliform/100 ml	-----	For Fecal Coliform Organism: - 0(Zero)no./100ml	No relaxation	

Analysis by:-

[Signature]
10/06/26
Chemists

[Signature]
10/6/26
In-charge

[Signature]
10/6/26
Assistant Engineer
DWS Amarpur Sub-Division
Amarpur Gomati Tripura

Sub-Divisional Water Testing Laboratory
DWS Sub-Division Amarpur
Amarpur, Gomati Tripura

Sub-Divisional Water Testing Laboratory
DWS Sub-Division Amarpur
Amarpur, Gomati Tripura

Sub-Divisional Water Testing Laboratory
DWS Sub-Division Amarpur
Amarpur, Gomati Tripura